

All of the cost numbers displayed in this document are before the application of on-going efficiencies and real price effects.

## PROJECT DETAILS

NAMP	1.36.03.3956	Region	EPN - Eastern Power Networks	RDP	RDP06
Category	Reinforcement	Description	EHV Reinforcement - Switchgear	Type	FL
Project	Little Barford 132/33kV Grid Substation - Replace 33kV Switchboard (Fault Level)				
Site/Route	Lt Barford Grid 33	Capacity Increase (MVA)	0.0		
Cost (ED1)	£1,700k	2012/13 Prices	NAMP version	Table J Less Indirect Baseline 19th February 2014	

Year	2015/16	2016/17	2017/18	2018/19	2019/20	2020/21	2021/22	2022/23
Spend Profile						£257k	£1443k	

## PROJECT APPROVAL

Approval has been granted as part of the Regional Development Plan.

## PROJECT NEED

The predicted fault level at Little Barford Grid Substation will exceed the rating of the existing switchgear due to increasing generation connections at EHV and HV. Twelve circuit breakers are Oil insulated EEC OKM4. The fault rating of the oil circuit breakers (circa 1984) is 17.5kA.

It is not possible to lower the fault level without compromising operational and planning requirements. It is therefore proposed to replace the existing 12 breaker AIS compound with a new installation comprising 12 circuit breakers.

## BACKGROUND

At present the potential fault current at Little Barford 33kV bars is 14kA which is within the switchgear rating of 17.5kA.

The three phase RMS fault level at Little Barford Grid 33kV is expected to increase by 2.8kA following the installation of a 3rd Super Grid Transformer at Eaton Socon in 2017 and by 2.0kA due to connection of 92MW of renewable generation in the Little Barford area.

This will result in a potential 3 phase fault level increase of 4.8kA which will result in fault level exceeding the switchgear rating.

## OPTIONEERING

The development of specific projects will involve revalidating the reinforcement need nearer the time and will consider applying traditional network reinforcement approaches or 'smart' solutions to deliver programme efficiencies. This may entail the use of solutions which have not been developed yet but are currently being researched.

All of the cost numbers displayed in this document are before the application of on-going efficiencies and real price effects.

## Options considered

Option 1 – Install new 33kV switchgear with the appropriate fault rating. Estimated cost £1,700k

PAIF Header / Category	Total
<b>Cabling Works</b>	<b>£157,532.74</b>
33kV Cables	£157,532.74
<b>Civil Works</b>	<b>£455,060.76</b>
Construction	£455,060.76
<b>Control / Protection Works</b>	<b>£177,116.61</b>
Protection Relay Panels	£143,291.36
SCADA	£33,825.25
<b>Site Engineering</b>	<b>£115,306.23</b>
Management & Prelims	£109,396.08
Testing & Commissioning	£5,910.15
<b>Substation Works</b>	<b>£769,176.42</b>
Electrical Installation Works	£769,176.42
<b>Sundry Items</b>	<b>£26,000.00</b>
Sundry Item	£26,000.00
<b>Grand Total</b>	<b>£1,700,192.76</b>

Option 2 – Operate the 33kV bars with the bus coupler open to reduce the fault level on each section. There are single transformer Primary substations connected to Lt Barford. The loss of one incoming 33kV supply will therefore cause loss of supply with consequent CI's and CML's until supply can be restored. This option also limits further connection of low carbon generation. This option is therefore rejected. One HI5 33kV breaker will need to be replaced. Estimated cost £140k.

Option 3 – Do Nothing. Continuing to operate the 33kV switchboard above its fault rating increases the risk of disruptive failure with consequent safety risks, CI's and CML's. This option is therefore rejected

## Recommended Option

Option 1 – This option provides a more resilient network for the connection of load and generation. Switchgear which would be approximately 40 years old by the end of the ED1 period will be replaced.

All of the cost numbers displayed in this document are before the application of on-going efficiencies and real price effects.

## OUTPUT MEASURES – LOAD INDICES (LI)

PLE information to Table CV102 (LI) – OFGEM definition and Element Energy growth forecast.

(1) 2011/12 Maximum demand growth based on Element Energy (as per the LRE narrative)

Site/Route	Lt Barford Grid 33	Capacity Increase	0.0 MVA	Year	2022	RIGS	CV101 113
Limitation	Switchgear	Season	W	Type of Intervention	FL	Optimised with NLRE	Yes
P2/6 Compliance (end of ED1)	Yes	P2/6 Class (end of ED1)	D				

	2010/11	2011/12	2012/13	2013/14	2014/15	2015/16	2016/17	2017/18	2018/19	2019/20	2020/21	2021/22	2022/23
Maximum Demand (MVA)	80.2	75.6	75.1	75.3	75.7	76.3	76.9	77.5	78.3	79.1	80.0	81.3	82.7
Firm Capacity without intervention (MVA)	114.3	114.3	114.3	114.3	114.3	114.3	114.3	114.3	114.3	114.3	114.3	114.3	114.3
Firm Capacity with intervention (MVA)													114.3
Load Index without Intervention	L11	L11	L11	L11	L11	L11	L11	L11	L11	L11	L11	L11	L11
Load Index with Intervention													L11

Note: The maximum demand at Little Barford Grid shown in the table above includes the contribution from distributed generation.

Fault level forecast based on EPN Long Term development Statement – Table 4A 3ph Fault Level (May 2013)

Substation	Node Name	Voltage Level (kV)	Existing System Fault Currents		Fault Rating	
			Peak Make (kA)	rms Break (kA)	Peak Make (kA)	Break (kA)
Little Barford 33kV	LBGD31	33.0	39.9	14.0	44.6	17.5
Network Modifications	(Contribution)		7.0	2.8		
Accepted Generation	(Contribution)		5.0	2.0		
<b>Forecast Fault Level</b>	<b>LBGD31</b>	<b>33.0</b>	<b>51.9</b>	<b>18.8</b>	<b>44.6</b>	<b>17.5</b>

## OUTPUT MEASURES – HEALTH INDICES (HI)

Asset Category	ED1 Start (2015)					ED1 End (2023) No Investment					End of ED1 (2023) With Investment				
	HI1	HI2	HI3	HI4	HI5	HI1	HI2	HI3	HI4	HI5	HI1	HI2	HI3	HI4	HI5
132kV Switchgear															
33kV Switchgear		11		1				9	2	1		12			
11/6.6kV Switchgear															
Grid/Primary Transformers															

## PROJECT RISK

# RIIO-ED1 Reinforcement Scheme Summary



All of the cost numbers displayed in this document are before the application of on-going efficiencies and real price effects.


General

- Details within the estimate have been done as desktop exercise only
- Potential impact of embedded generation within the wider network

Name	Title	Signature	Date
D J Whiteley	Infrastructure Planner	D J Whiteley	28/02/2014
Name	Title	Signature	Date
Robert Kemp	Head of System Development		28/02/2014
Name	Title	Signature	Date
Barry Hatton	Director of Asset Management		

All of the cost numbers displayed in this document are before the application of on-going efficiencies and real price effects.


## SINGLE LINE DIAGRAM – EXISTING NETWORK




## SINGLE LINE DIAGRAM – RECOMMENDED OPTION

# RIIO-ED1 Reinforcement Scheme Summary

All of the cost numbers displayed in this document are before the application of on-going efficiencies and real price effects.



## GEOGRAPHICAL DIAGRAM



## AERIAL VIEW – LITTLE BARFORD 33

# RIIO-ED1 Reinforcement Scheme Summary

All of the cost numbers displayed in this document are before the application of on-going efficiencies and real price effects.

